









ISO 9001 CERTIFIED COMPANY

CS-8 Cast Steel Swing Check Valve Flanged, Class-150 (IBR Approved)

Product Description HSN 84813000

Product: 'SANT' Cast Steel Swing Check Valve Product Standard: BS 1868 / ANSI B16.34 Pressure / Class / Rating: Class-150

Body Material cum Standard: CCS (ASTM A216 Gr.WCB)

Description: Bolted Cover Type of Seat: Renewable seat Type of Disc: Renewable disc Hinge Pin: SS AISI-410

End Details: Flanges as per ANSI B 16.5 Class 150 R.F. Undrilled

Testing & Certification


Body Test Pressure : 30 Bar g Hyd. (435 Psig) Seat Test Pressure : 22 Bar g Hyd. (320 Psig)

Seat is also tested at low pressure of 25% of the above test Tested as per API 598 / ANSI B16.34 / BS : 6755 Part 1

Max Working Temperature: 400°C

Test Certificate in Form III-C as per IBR is furnished with every supply.

Application




Materials of Construction

Components	Materials	Specifications	
Body, Cover, Valve Disc	Cast Carbon Steel	ASTM A216 Gr.WCB	
Gasket	CAF	BS:1832	
Body Rings, Disc Seat, Pin & Side Plugs	Stainless Steel	AISI-410	
Bolts	Alloy Steel	ASTM A193 Gr.B7	
Nuts	HT Steel	ASTM A194 Gr.2H	
Lever	M.I. / S.G. Iron	_	

Dimensions (in mm)

Nominal Size	Nominal Size (Inches)	F	H (Approx)	
25	1	127±2	115	
40	1.1/2	165±2	130	
50	2	203±2	145	
65	2.1/2	216±2	155	
80	3	241±2	175	
100	4	292±2	200	
125	5	330±2	210	
150	6	356±2	240	
200	8	495±3	275	



Notes

- 1. Product images are for illustration purposes only. Actual product may vary.
- 2. Actual dimensions may change over time, due to continual design improvements. Please confirm before placing order.

Sant Valves Pvt. Ltd. G.T.Road Bye Pass, Jalandhar - 144012. Punjab. INDIA Phone: +91 181 5084693 Fax: +91 181 5062270 Email: info@santvalves.com